

Lab. ID # 113833

To:	Franklin Health Dept. Attn: Cathleen Liberty 355 E. Central St. Franklin, MA 02038
------------	---

Received Date/Time:	8/14/24, 5:50 PM
Analyzed Date/Time:	8/14/24, 6:00 PM
Reported Date:	8/15/24
Collected by:	Client
Collected Date:	8/14/24

ANALYTICAL RESULTS

Sample #	Sampling Location	Sampling Time	E. coli (CFU/100mL)	GeoMean
1	Chilson Beach	10:00 AM	400*	
Maximum Contaminant Level			235	126
Method of Reference			EPA 1603	

Laboratory QC Results

QC	Unit	E. coli
Duplicate (D1)	100mL	20
Duplicate (D2)	100mL	20
Dilution Blk.(Beginning)	100mL	Negative
Dilution Blk.(Ending)	100mL	Negative
Positive Control	100mL	Positive

*: Exceeds MCL

Approved By: _____

Diana F. 8/16/24

Lab. Director

Date

