

Lab. ID #
112252
To: Franklin Health Dept.
 Attn: Cathleen Liberty
 355 E. Central St.
 Franklin, MA 02038

Received Date/Time:	6/5/24, 1:45 PM
Analyzed Date/Time:	6/5/24, 2:15 PM
Reported Date:	6/6/24
Collected by:	Client
Collected Date:	6/5/24

ANALYTICAL RESULTS

Sample #	Sampling Location	Sampling Time	E. coli (CFU/100mL)	GeoMean
1	Chilson Beach	10:00 AM	12	
Maximum Contaminant Level			235	126
Method of Reference			EPA 1603	

Laboratory QC Results

QC	Unit	E. coli
Duplicate (D1)	100mL	<5
Duplicate (D2)	100mL	<5
Dilution Blk.(Beginning)	100mL	Negative
Dilution Blk.(Ending)	100mL	Negative
Positive Control	100mL	Positive

Approved By:


Lab. Director

6/7/24

Date

